

## VYPRODUKOVANÉ EMISIE DECEMBER 2017

### Kompresorová stanica 01 Veľké Kapušany

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )	
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>
NP	0,323	0,820	10,03	38,74	100	75
CR1	0,143	0,302	4,02	61,37	100	75
CR3	1,171	1,440	35,34	56,84	100	75
CR4	0,389	1,639	16,29	61,47	100	75
R5	1,082	2,176	13,83	27,07	100	75
R6	1,767	2,766	22,90	35,12	100	75

### Kompresorová stanica 02 Jablonov nad Turňou

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )	
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>
CR1	-	-	-	-	100	150
CR2	-	-	-	-	100	150

### Kompresorová stanica 03 Veľké Zlievce

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )	
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>
NP1	-	-	-	-	100	75
NP2	-	-	-	-	100	75
R1	-	-	-	-	100	75
R2	-	-	-	-	100	75

### Kompresorová stanica 04 Ivanka pri Nitre

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )	
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>
NP1	-	-	-	-	100	75
NP2	-	-	-	-	100	370
NP3	-	-	-	-	100	370
NP4	-	-	-	-	100	370

#### Vysvetlivky

**PMH** Priemerná mesačná hodnota