

VYPRODUKOVANÉ EMISIE JÚL 2017

Kompresorová stanica 01 Veľké Kapušany

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)	
	CO	NO _x	CO	NO _x	CO	NO _x
NP	2,192	2,039	35,80	32,14	100	75
CR1	0,111	1,304	1,840	55,46	100	75
CR3	0,143	0,191	13,22	62,18	100	75
CR4	0,464	4,324	4,150	60,72	100	75
R5	0,365	1,983	6,280	34,34	100	75
R6	2,520	2,808	22,68	26,56	100	75

Kompresorová stanica 02 Jablonov nad Turňou

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)	
	CO	NO _x	CO	NO _x	CO	NO _x
CR1	-	-	-	-	100	150
CR2	-	-	-	-	100	150

Kompresorová stanica 03 Veľké Zlievce

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)	
	CO	NO _x	CO	NO _x	CO	NO _x
NP1	-	-	-	-	100	75
NP2	-	-	-	-	100	75
R1	0,011	0,008	37,73	46,55	100	75
R2	1,890	1,401	47,05	39,90	100	75

Kompresorová stanica 04 Ivanka pri Nitre

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)	
	CO	NO _x	CO	NO _x	CO	NO _x
NP1	-	-	-	-	100	75
NP2	-	-	-	-	100	370
NP3	-	-	-	-	100	370
NP4	-	-	-	-	100	370

Vysvetlivky

PMH Priemerná mesačná hodnota