

## VYPRODUKOVANÉ EMISIE JÚN 2017

### Kompresorová stanica 01 Veľké Kapušany

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )	
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>
NP	0,372	0,319	37,60	30,77	100	75
CR1	0,248	2,350	2,87	60,24	100	75
CR3	0,242	1,198	4,65	60,05	100	75
CR4	0,431	4,628	4,07	64,09	100	75
R5	0,631	3,991	5,08	31,54	100	75
R6	1,995	3,490	16,75	29,10	100	75

### Kompresorová stanica 02 Jablonov nad Turňou

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )	
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>
CR1	-	-	-	-	100	150
CR2	-	-	-	-	100	150

### Kompresorová stanica 03 Veľké Zlievce

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )	
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>
NP1	0,001	0,007	5,77	48,48	100	75
NP2	-	-	-	-	100	75
R1	0,023	0,009	73,17	47,33	100	75
R2	0,507	0,446	42,10	37,66	100	75

### Kompresorová stanica 04 Ivanka pri Nitre

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )	
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>
NP1	-	-	-	-	100	75
NP2	-	-	-	-	100	370
NP3	-	-	-	-	100	370
NP4	-	-	-	-	100	370

#### Vysvetlivky

**PMH** Priemerná mesačná hodnota