

VYPRODUKOVANÉ EMISIE MÁJ 2017

Kompresorová stanica 01 Veľké Kapušany

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)	
	CO	NO _x	CO	NO _x	CO	NO _x
NP	0,972	1,073	37,13	30,44	100	75
CR1	0,211	6,142	1,67	63,17	100	75
CR3	0,226	0,979	4,52	58,50	100	75
CR4	0,656	9,115	4,25	64,96	100	75
R5	0,264	1,656	6,62	40,53	100	75
R6	1,678	4,901	12,12	34,88	100	75

Kompresorová stanica 02 Jablonov nad Turňou

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)	
	CO	NO _x	CO	NO _x	CO	NO _x
CR1	-	-	-	-	100	150
CR2	-	-	-	-	100	150

Kompresorová stanica 03 Veľké Zlievce

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)	
	CO	NO _x	CO	NO _x	CO	NO _x
NP1	0,010	0,061	8,50	51,99	100	75
NP2	0,019	0,034	19,93	35,61	100	75
R1	0,124	0,139	42,25	57,29	100	75
R2	0,055	0,055	44,70	44,76	100	75

Kompresorová stanica 04 Ivanka pri Nitre

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)	
	CO	NO _x	CO	NO _x	CO	NO _x
NP1	-	-	-	-	100	75
NP2	-	-	-	-	100	370
NP3	-	-	-	-	100	370
NP4	-	-	-	-	100	370

Vysvetlivky

PMH Priemerná mesačná hodnota