

VYPRODUKOVANÉ EMISIE NOVEMBER 2017

Kompresorová stanica 01 Veľké Kapušany

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)	
	CO	NO _x	CO	NO _x	CO	NO _x
NP	4,185	3,139	47,08	34,05	100	75
CR1	0,349	1,141	4,14	61,71	100	75
CR3	2,502	3,535	27,31	53,53	100	75
CR4	1,036	1,310	28,96	54,62	100	75
R5	0,821	4,985	7,16	42,53	100	75
R6	0,055	0,178	8,96	31,37	100	75

Kompresorová stanica 02 Jablonov nad Turňou

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)	
	CO	NO _x	CO	NO _x	CO	NO _x
CR1	-	-	-	-	100	150
CR2	-	-	-	-	100	150

Kompresorová stanica 03 Veľké Zlievce

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)	
	CO	NO _x	CO	NO _x	CO	NO _x
NP1	-	-	-	-	100	75
NP2	0,002	0,001	-	-	100	75
R1	-	-	-	-	100	75
R2	0,206	0,024	-	-	100	75

Kompresorová stanica 04 Ivanka pri Nitre

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)	
	CO	NO _x	CO	NO _x	CO	NO _x
NP1	-	-	-	-	100	75
NP2	-	-	-	-	100	370
NP3	-	-	-	-	100	370
NP4	-	-	-	-	100	370

Vysvetlivky

PMH Priemerná mesačná hodnota