

VYPRODUKOVANÉ EMISIE OKTÓBER 2017

Kompresorová stanica 01 Veľké Kapušany

| PLYNOVÁ TURBÍNA | t/mesiac | | PMH (mg/m ³) | | Emisný limit (mg/m ³) | |
|--------------------|----------|-----------------|--------------------------|-----------------|-----------------------------------|-----------------|
| | CO | NO _x | CO | NO _x | CO | NO _x |
| NP | 1,918 | 1,207 | 53,22 | 32,00 | 100 | 75 |
| CR1 | - | - | - | - | 100 | 75 |
| CR3 | 0,682 | 0,638 | 34,78 | 48,68 | 100 | 75 |
| CR4 | 1,336 | 2,277 | 24,91 | 52,96 | 100 | 75 |
| R5 | 1,719 | 4,755 | 11,76 | 32,19 | 100 | 75 |
| R6 | - | - | - | - | 100 | 75 |

Kompresorová stanica 02 Jablonov nad Turňou

| PLYNOVÁ TURBÍNA | t/mesiac | | PMH (mg/m ³) | | Emisný limit (mg/m ³) | |
|--------------------|----------|-----------------|--------------------------|-----------------|-----------------------------------|-----------------|
| | CO | NO _x | CO | NO _x | CO | NO _x |
| CR1 | - | - | - | - | 100 | 150 |
| CR2 | - | - | - | - | 100 | 150 |

Kompresorová stanica 03 Veľké Zlievce

| PLYNOVÁ TURBÍNA | t/mesiac | | PMH (mg/m ³) | | Emisný limit (mg/m ³) | |
|--------------------|----------|-----------------|--------------------------|-----------------|-----------------------------------|-----------------|
| | CO | NO _x | CO | NO _x | CO | NO _x |
| NP1 | - | - | - | - | 100 | 75 |
| NP2 | 0,005 | 0,003 | - | - | 100 | 75 |
| R1 | 0,069 | 0,002 | - | - | 100 | 75 |
| R2 | 0,046 | 0,003 | - | - | 100 | 75 |

Kompresorová stanica 04 Ivanka pri Nitre

| PLYNOVÁ TURBÍNA | t/mesiac | | PMH (mg/m ³) | | Emisný limit (mg/m ³) | |
|--------------------|----------|-----------------|--------------------------|-----------------|-----------------------------------|-----------------|
| | CO | NO _x | CO | NO _x | CO | NO _x |
| NP1 | 0,004 | 0,044 | - | - | 100 | 75 |
| NP2 | 0,005 | 0,239 | 5,79 | 266,44 | 100 | 370 |
| NP3 | - | - | - | - | 100 | 370 |
| NP4 | - | - | - | - | 100 | 370 |

Vysvetlivky

PMH Priemerná mesačná hodnota