

## VYPRODUKOVANÉ EMISIE APRÍL 2018

### Kompresorová stanica 01 Veľké Kapušany

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )	
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>
NP	1,949	1,182	54,54	31,28	100	75
CR1	0,249	6,013	1,86	64,22	100	75
CR3	0,376	2,389	8,92	61,07	100	75
CR4	0,392	2,990	6,45	59,72	100	75
R5	4,974	2,774	42,23	32,00	100	75
R6	3,733	5,933	26,37	40,46	100	75

### Kompresorová stanica 02 Jablonov nad Turňou

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )	
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>
CR1	-	-	-	-	100	150
CR2	-	-	-	-	100	150

### Kompresorová stanica 03 Veľké Zlievce

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )	
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>
NP1	0,514	0,412	49,68	38,27	100	75
NP2	0,131	0,004	476,24*	15,81*	100	75
R1	3,979	3,949	47,87	46,51	100	75
R2	3,440	2,474	38,50	29,30	100	75

\*prevádzka plynovej turbíny pri zaťažení nižšom ako 70%. Výnimka v zmysle § 18 ods. 5 písm. c) vyhlášky MŽP SR č. 410/2012

### Kompresorová stanica 04 Ivanka pri Nitre

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )	
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>
NP1	-	-	-	-	100	75
NP2	-	-	-	-	100	370
NP3	-	-	-	-	100	370
NP4	-	-	-	-	100	370

#### Vysvetlivky

PMH Priemerná mesačná hodnota