

## VYPRODUKOVANÉ EMISIE FEBRUÁR 2018

### Kompresorová stanica 01 Veľké Kapušany

| PLYNOVÁ<br>TURBÍNA | t/mesiac |                 | PMH (mg/m <sup>3</sup> ) |                 | Emisný limit (mg/m <sup>3</sup> ) |                 |
|--------------------|----------|-----------------|--------------------------|-----------------|-----------------------------------|-----------------|
|                    | CO       | NO <sub>x</sub> | CO                       | NO <sub>x</sub> | CO                                | NO <sub>x</sub> |
| NP                 | 0,902    | 0,694           | 49,34                    | 56,65           | 100                               | 75              |
| CR1                | 0,226    | 0,930           | 5,60                     | 65,55           | 100                               | 75              |
| CR3                | -        | -               | -                        | -               | 100                               | 75              |
| CR4                | -        | -               | -                        | -               | 100                               | 75              |
| R5                 | 0,476    | 1,354           | 11,57                    | 27,91           | 100                               | 75              |
| R6                 | 1,757    | 1,602           | 35,87                    | 34,79           | 100                               | 75              |

### Kompresorová stanica 02 Jablonov nad Turňou

| PLYNOVÁ<br>TURBÍNA | t/mesiac |                 | PMH (mg/m <sup>3</sup> ) |                 | Emisný limit (mg/m <sup>3</sup> ) |                 |
|--------------------|----------|-----------------|--------------------------|-----------------|-----------------------------------|-----------------|
|                    | CO       | NO <sub>x</sub> | CO                       | NO <sub>x</sub> | CO                                | NO <sub>x</sub> |
| CR1                | -        | -               | -                        | -               | 100                               | 150             |
| CR2                | -        | -               | -                        | -               | 100                               | 150             |

### Kompresorová stanica 03 Veľké Zlievce

| PLYNOVÁ<br>TURBÍNA | t/mesiac |                 | PMH (mg/m <sup>3</sup> ) |                 | Emisný limit (mg/m <sup>3</sup> ) |                 |
|--------------------|----------|-----------------|--------------------------|-----------------|-----------------------------------|-----------------|
|                    | CO       | NO <sub>x</sub> | CO                       | NO <sub>x</sub> | CO                                | NO <sub>x</sub> |
| NP1                | -        | -               | -                        | -               | 100                               | 75              |
| NP2                | -        | -               | -                        | -               | 100                               | 75              |
| R1                 | 0,433    | 0,213           | 76,35                    | 53,09           | 100                               | 75              |
| R2                 | 0,238    | 0,048           | 155,95                   | 39,34           | 100                               | 75              |

### Kompresorová stanica 04 Ivanka pri Nitre

| PLYNOVÁ<br>TURBÍNA | t/mesiac |                 | PMH (mg/m <sup>3</sup> ) |                 | Emisný limit (mg/m <sup>3</sup> ) |                 |
|--------------------|----------|-----------------|--------------------------|-----------------|-----------------------------------|-----------------|
|                    | CO       | NO <sub>x</sub> | CO                       | NO <sub>x</sub> | CO                                | NO <sub>x</sub> |
| NP1                | -        | -               | -                        | -               | 100                               | 75              |
| NP2                | -        | -               | -                        | -               | 100                               | 370             |
| NP3                | -        | -               | -                        | -               | 100                               | 370             |
| NP4                | -        | -               | -                        | -               | 100                               | 370             |

#### Vysvetlivky

**PMH** Priemerná mesačná hodnota