

VYPRODUKOVANÉ EMISIE MAREC 2018

Kompresorová stanica 01 Veľké Kapušany

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)	
	CO	NO _x	CO	NO _x	CO	NO _x
NP	6,645	4,265	51,80	33,75	100	75
CR1	-	-	-	-	100	75
CR3	2,962	2,867	43,79	54,44	100	75
CR4	0,617	0,883	20,69	52,99	100	75
R5	4,383	2,472	31,23	20,73	100	75
R6	1,699	0,558	68,89	25,91	100	75

Kompresorová stanica 02 Jablonov nad Turňou

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)	
	CO	NO _x	CO	NO _x	CO	NO _x
CR1	-	-	-	-	100	150
CR2	-	-	-	-	100	150

Kompresorová stanica 03 Veľké Zlievce

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)	
	CO	NO _x	CO	NO _x	CO	NO _x
NP1	-	-	-	-	100	75
NP2	-	-	-	-	100	75
R1	1,249	1,148	42,53	48,27	100	75
R2	0,177	0,061	43,72	36,01	100	75

Kompresorová stanica 04 Ivanka pri Nitre

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)	
	CO	NO _x	CO	NO _x	CO	NO _x
NP1	-	-	-	-	100	75
NP2	-	-	-	-	100	370
NP3	-	-	-	-	100	370
NP4	-	-	-	-	100	370

Vysvetlivky

PMH Priemerná mesačná hodnota