

VYPRODUKOVANÉ EMISIE AUGUST 2018

Kompresorová stanica 01 Veľké Kapušany

| PLYNOVÁ TURBÍNA | t/mesiac | | PMH (mg/m ³) | | Emisný limit (mg/m ³) | |
|--------------------|----------|-----------------|--------------------------|-----------------|-----------------------------------|-----------------|
| | CO | NO _x | CO | NO _x | CO | NO _x |
| NP | 0.589 | 5.556 | 14.43 | 33.15 | 100 | 75 |
| CR1 | 0.141 | 1.338 | 3.32 | 55.38 | 100 | 75 |
| CR3 | 0.155 | 1.159 | 5.24 | 62.14 | 100 | 75 |
| CR4 | 0.321 | 2.384 | 6.14 | 55.94 | 100 | 75 |
| R5 | 3.210 | 2.511 | 43.33 | 33.08 | 100 | 75 |
| R6 | 4.095 | 4.216 | 27.24 | 31.62 | 100 | 75 |

Kompresorová stanica 02 Jablonov nad Turňou

| PLYNOVÁ TURBÍNA | t/mesiac | | PMH (mg/m ³) | | Emisný limit (mg/m ³) | |
|--------------------|----------|-----------------|--------------------------|-----------------|-----------------------------------|-----------------|
| | CO | NO _x | CO | NO _x | CO | NO _x |
| CR1 | - | - | - | - | 100 | 150 |
| CR2 | - | - | - | - | 100 | 150 |

Kompresorová stanica 03 Veľké Zlievce

| PLYNOVÁ TURBÍNA | t/mesiac | | PMH (mg/m ³) | | Emisný limit (mg/m ³) | |
|--------------------|----------|-----------------|--------------------------|-----------------|-----------------------------------|-----------------|
| | CO | NO _x | CO | NO _x | CO | NO _x |
| NP1 | - | - | - | - | 100 | 75 |
| NP2 | - | - | - | - | 100 | 75 |
| R1 | - | - | - | - | 100 | 75 |
| R2 | 0.654 | 0.763 | 30.86 | 37.14 | 100 | 75 |

Kompresorová stanica 04 Ivanka pri Nitre

| PLYNOVÁ TURBÍNA | t/mesiac | | PMH (mg/m ³) | | Emisný limit (mg/m ³) | |
|--------------------|----------|-----------------|--------------------------|-----------------|-----------------------------------|-----------------|
| | CO | NO _x | CO | NO _x | CO | NO _x |
| NP1 | - | - | - | - | 100 | 75 |
| NP2 | - | - | - | - | 100 | 370 |
| NP3 | - | - | - | - | 100 | 370 |
| NP4 | - | - | - | - | 100 | 370 |

Vysvetlivky

PMH Priemerná mesačná hodnota