

VYPRODUKOVANÉ EMISIE JÚL 2018

Kompresorová stanica 01 Veľké Kapušany

| PLYNOVÁ TURBÍNA | t/mesiac | | PMH (mg/m ³) | | Emisný limit (mg/m ³) | |
|--------------------|----------|-----------------|--------------------------|-----------------|-----------------------------------|-----------------|
| | CO | NO _x | CO | NO _x | CO | NO _x |
| NP | 1,205 | 1,902 | 16,10 | 32,55 | 100 | 75 |
| CR1 | 0,238 | 1,566 | 1,65 | 59,51 | 100 | 75 |
| CR3 | 0,272 | 2,141 | 4,37 | 64,42 | 100 | 75 |
| CR4 | 0,487 | 5,201 | 3,77 | 58,33 | 100 | 75 |
| R5 | 4,451 | 5,421 | 31,45 | 37,74 | 100 | 75 |
| R6 | 2,783 | 5,146 | 19,40 | 36,67 | 100 | 75 |

Kompresorová stanica 02 Jablonov nad Turňou

| PLYNOVÁ TURBÍNA | t/mesiac | | PMH (mg/m ³) | | Emisný limit (mg/m ³) | |
|--------------------|----------|-----------------|--------------------------|-----------------|-----------------------------------|-----------------|
| | CO | NO _x | CO | NO _x | CO | NO _x |
| CR1 | - | - | - | - | 100 | 150 |
| CR2 | - | - | - | - | 100 | 150 |

Kompresorová stanica 03 Veľké Zlievce

| PLYNOVÁ TURBÍNA | t/mesiac | | PMH (mg/m ³) | | Emisný limit (mg/m ³) | |
|--------------------|----------|-----------------|--------------------------|-----------------|-----------------------------------|-----------------|
| | CO | NO _x | CO | NO _x | CO | NO _x |
| NP1 | 0,167 | 0,418 | 15,46 | 39,22 | 100 | 75 |
| NP2 | 0,130 | 0,568 | 8,10 | 37,72 | 100 | 75 |
| R1 | 1,708 | 2,461 | 34,26 | 48,75 | 100 | 75 |
| R2 | 1,556 | 1,916 | 30,39 | 39,15 | 100 | 75 |

Kompresorová stanica 04 Ivanka pri Nitre

| PLYNOVÁ TURBÍNA | t/mesiac | | PMH (mg/m ³) | | Emisný limit (mg/m ³) | |
|--------------------|----------|-----------------|--------------------------|-----------------|-----------------------------------|-----------------|
| | CO | NO _x | CO | NO _x | CO | NO _x |
| NP1 | - | - | - | - | 100 | 75 |
| NP2 | - | - | - | - | 100 | 370 |
| NP3 | - | - | - | - | 100 | 370 |
| NP4 | - | - | - | - | 100 | 370 |

Vysvetlivky

PMH Priemerná mesačná hodnota