

## VYPRODUKOVANÉ EMISIE SEPTEMBER 2018

### Kompresorová stanica 01 Veľké Kapušany

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )	
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>
NP	1.167	1.248	6.90	34.64	100	75
CR1	0.353	1.661	1.99	61.87	100	75
CR3	0.092	0.172	11.41	49.14	100	75
CR4	1.125	1.955	9.45	59.38	100	75
R5	2.523	1.899	32.30	29.04	100	75
R6	3.973	3.131	21.31	28.61	100	75

### Kompresorová stanica 02 Jablonov nad Turňou

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )	
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>
CR1	-	-	-	-	100	150
CR2	-	-	-	-	100	150

### Kompresorová stanica 03 Veľké Zlievce

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )	
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>
NP1	-	-	-	-	100	75
NP2	-	-	-	-	100	75
R1	0.225	0.179	40.03	49.94	100	75
R2	0.574	0.857	23.07	38.69	100	75

### Kompresorová stanica 04 Ivanka pri Nitre

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )	
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>
NP1	-	-	-	-	100	75
NP2	-	-	-	-	100	370
NP3	-	-	-	-	100	370
NP4	-	-	-	-	100	370

#### Vysvetlivky

**PMH** Priemerná mesačná hodnota