

VYPRODUKOVANÉ EMISIE APRÍL 2019

Kompresorová stanica 01 Veľké Kapušany

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)		Súlad
	CO	NO _x	CO	NO _x	CO	NO _x	
NP	1.153	4.435	11.84	46.14	100	75	✓
CR1	0.359	5.213	2.89	62.94	100	75	✓
CR3	0.830	1.804	15.07	62.63	100	75	✓
CR4	0.819	6.304	7.97	63.62	100	75	✓
R5	0.955	5.888	7.00	42.68	100	75	✓
R6	0.301	1.851	6.45	39.07	100	75	✓

Kompresorová stanica 02 Jablonov nad Turňou

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)		Súlad
	CO	NO _x	CO	NO _x	CO	NO _x	
CR1	-	-	-	-	100	150	✓
CR2	-	-	-	-	100	150	✓

Kompresorová stanica 03 Veľké Zlievce

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)		Súlad
	CO	NO _x	CO	NO _x	CO	NO _x	
NP1	1.092	1.013	52.89	43.34	100	75	✓
NP2	0.005	0.005	-	-	100	75	✓
R1	1.517	1.573	51.26	51.31	100	75	✓
R2	3.056	4.481	25.02	35.03	100	75	✓

Kompresorová stanica 04 Ivanka pri Nitre

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)		Súlad
	CO	NO _x	CO	NO _x	CO	NO _x	
NP1	-	-	-	-	100	75	✓
NP2	-	-	-	-	100	370	✓
NP3	-	-	-	-	100	370	✓
NP4	-	-	-	-	100	370	✓

Vysvetlivky

PMH Priemerná mesačná hodnota

✓ Hodnoty vyprodukovaných emisií sú v súlade s integrovaným povolením