

VYPRODUKOVANÉ EMISIE AUGUST 2019

Kompresorová stanica 01 Veľké Kapušany

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)		Súlada
	CO	NO _x	CO	NO _x	CO	NO _x	
NP	0.061	0.103	27.70	32.90	100	75	✓
CR1	0.040	0.093	2.61	56.75	100	75	✓
CR3	-	-	-	-	100	75	✓
CR4	0.102	0.299	7.77	55.21	100	75	✓
R5	1.453	4.058	10.62	31.30	100	75	✓
R6	0.950	2.065	10.28	24.29	100	75	✓

Kompresorová stanica 02 Jablonov nad Turňou

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)		Súlada
	CO	NO _x	CO	NO _x	CO	NO _x	
CR1	-	-	-	-	100	150	✓
CR2	-	-	-	-	100	150	✓

Kompresorová stanica 03 Veľké Zlievce

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)		Súlada
	CO	NO _x	CO	NO _x	CO	NO _x	
NP1	0.009	0.013	28.18	37.72	100	75	✓
NP2	0.020	0.030	22.59	36.16	100	75	✓
R1	0.011	0.012	-	-	100	75	✓
R2	-	-	-	-	100	75	✓

Kompresorová stanica 04 Ivanka pri Nitre

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)		Súlada
	CO	NO _x	CO	NO _x	CO	NO _x	
NP1	-	-	-	-	100	75	✓
NP2	-	-	-	-	100	370	✓
NP3	-	-	-	-	100	370	✓
NP4	-	-	-	-	100	370	✓

Vysvetlivky

PMH Priemerná mesačná hodnota

✓ Hodnoty vyprodukovaných emisií sú v súlade s integrovaným povolením