

## VYPRODUKOVANÉ EMISIE FEBRUÁR 2019

### Kompresorová stanica 01 Veľké Kapušany

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )		Súlad
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	
NP	1.136	1.687	25.47	37.46	100	75	✓
CR1	-	-	-	-	100	75	✓
CR3	-	-	-	-	100	75	✓
CR4	0.255	0.478	24.48	61.04	100	75	✓
R5	1.047	4.970	7.83	37.94	100	75	✓
R6	0.832	4.008	6.95	34.85	100	75	✓

### Kompresorová stanica 02 Jablonov nad Turňou

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )		Súlad
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	
CR1	-	-	-	-	100	150	✓
CR2	-	-	-	-	100	150	✓

### Kompresorová stanica 03 Veľké Zlievce

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )		Súlad
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	
NP1	-	-	-	-	100	75	✓
NP2	-	-	-	-	100	75	✓
R1	0.061	0.051	-	-	100	75	✓
R2	0.053	0.056	-	-	100	75	✓

### Kompresorová stanica 04 Ivanka pri Nitre

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )		Súlad
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	
NP1	-	-	-	-	100	75	✓
NP2	-	-	-	-	100	370	✓
NP3	-	-	-	-	100	370	✓
NP4	-	-	-	-	100	370	✓

#### Vysvetlivky

**PMH** Priemerná mesačná hodnota

✓ Hodnoty vyprodukovaných emisií sú v súlade s integrovaným povolením