

VYPRODUKOVANÉ EMISIE JANUÁR 2019

Kompresorová stanica 01 Veľké Kapušany

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)		Súlada
	CO	NO _x	CO	NO _x	CO	NO _x	
NP	2.303	4.032	24.08	43.67	100	75	✓
CR1	0.407	2.380	7.13	64.77	100	75	✓
CR3	0.292	0.212	39.94	55.59	100	75	✓
CR4	2.605	6.724	14.61	66.00	100	75	✓
R5	0.707	5.131	6.29	46.03	100	75	✓
R6	0.452	3.038	5.83	39.75	100	75	✓

Kompresorová stanica 02 Jablonov nad Turňou

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)		Súlada
	CO	NO _x	CO	NO _x	CO	NO _x	
CR1	-	-	-	-	100	150	✓
CR2	-	-	-	-	100	150	✓

Kompresorová stanica 03 Veľké Zlievce

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)		Súlada
	CO	NO _x	CO	NO _x	CO	NO _x	
NP1	0.026	0.011	-	-	100	75	✓
NP2	0.026	0.012	-	-	100	75	✓
R1	0.644	0.444	79.83	52.18	100	75	✓
R2	0.061	0.054	-	-	100	75	✓

Kompresorová stanica 04 Ivanka pri Nitre

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)		Súlada
	CO	NO _x	CO	NO _x	CO	NO _x	
NP1	0.037	0.134	-	-	100	75	✓
NP2	-	-	-	-	100	370	✓
NP3	-	-	-	-	100	370	✓
NP4	-	-	-	-	100	370	✓

Vysvetlivky

PMH Priemerná mesačná hodnota

✓ Hodnoty vyprodukovaných emisií sú v súlade s integrovaným povolením