

## VYPRODUKOVANÉ EMISIE JÚL 2019

### Kompresorová stanica 01 Veľké Kapušany

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )		Súlada
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	
NP	0.762	2.689	8.40	43.16	100	75	✓
CR1	0.287	3.716	2.10	59.53	100	75	✓
CR3	0.610	0.751	21.51	57.80	100	75	✓
CR4	1.089	6.262	7.87	58.35	100	75	✓
R5	1.111	3.343	9.36	29.80	100	75	✓
R6	1.155	3.521	7.84	25.25	100	75	✓

### Kompresorová stanica 02 Jablonov nad Turňou

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )		Súlada
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	
CR1	-	-	-	-	100	150	✓
CR2	-	-	-	-	100	150	✓

### Kompresorová stanica 03 Veľké Zlievce

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )		Súlada
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	
NP1	-	-	-	-	100	75	✓
NP2	-	-	-	-	100	75	✓
R1	0.507	0.839	30.14	48.43	100	75	✓
R2	0.990	1.709	21.73	38.90	100	75	✓

### Kompresorová stanica 04 Ivanka pri Nitre

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )		Súlada
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	
NP1	0.092	0.244	-	-	100	75	✓
NP2	-	-	-	-	100	370	✓
NP3	-	-	-	-	100	370	✓
NP4	-	-	-	-	100	370	✓

#### Vysvetlivky

**PMH** Priemerná mesačná hodnota

✓ Hodnoty vyprodukovaných emisií sú v súlade s integrovaným povolením