

VYPRODUKOVANÉ EMISIE JÚN 2019

Kompresorová stanica 01 Veľké Kapušany

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)		Súlada
	CO	NO _x	CO	NO _x	CO	NO _x	
NP	0.665	1.536	10.61	36.41	100	75	✓
CR1	0.497	5.625	2.46	58.79	100	75	✓
CR3	1.659	4.153	17.92	58.19	100	75	✓
CR4	0.124	0.855	8.64	57.88	100	75	✓
R5	1.040	2.796	11.04	31.49	100	75	✓
R6	0.965	3.192	6.75	24.50	100	75	✓

Kompresorová stanica 02 Jablonov nad Turňou

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)		Súlada
	CO	NO _x	CO	NO _x	CO	NO _x	
CR1	-	-	-	-	100	150	✓
CR2	-	-	-	-	100	150	✓

Kompresorová stanica 03 Veľké Zlievce

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)		Súlada
	CO	NO _x	CO	NO _x	CO	NO _x	
NP1	-	-	-	-	100	75	✓
NP2	-	-	-	-	100	75	✓
R1	0.877	1.019	37.20	46.30	100	75	✓
R2	-	-	-	-	100	75	✓

Kompresorová stanica 04 Ivanka pri Nitre

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)		Súlada
	CO	NO _x	CO	NO _x	CO	NO _x	
NP1	-	-	-	-	100	75	✓
NP2	0.000	0.035	0.80	242.91	100	370	✓
NP3	-	-	-	-	100	370	✓
NP4	-	-	-	-	100	370	✓

Vysvetlivky

PMH Priemerná mesačná hodnota

✓ Hodnoty vyprodukovaných emisií sú v súlade s integrovaným povolením