

VYPRODUKOVANÉ EMISIE MAREC 2019

Kompresorová stanica 01 Veľké Kapušany

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)		Súlady
	CO	NO _x	CO	NO _x	CO	NO _x	
NP	2.488	3.744	26.52	38.09	100	75	✓
CR1	0.146	1.483	3.28	63.44	100	75	✓
CR3	0.360	0.317	39.53	54.18	100	75	✓
CR4	0.254	1.111	7.87	63.45	100	75	✓
R5	1.103	5.142	8.36	38.03	100	75	✓
R6	1.165	5.363	8.02	36.11	100	75	✓

Kompresorová stanica 02 Jablonov nad Turňou

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)		Súlady
	CO	NO _x	CO	NO _x	CO	NO _x	
CR1	-	-	-	-	100	150	✓
CR2	-	-	-	-	100	150	✓

Kompresorová stanica 03 Veľké Zlievce

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)		Súlady
	CO	NO _x	CO	NO _x	CO	NO _x	
NP1	0.006	0.013	7.99	45.90	100	75	✓
NP2	-	-	-	-	100	75	✓
R1	1.798	1.683	58.37	55.15	100	75	✓
R2	0.049	0.005	-	-	100	75	✓

Kompresorová stanica 04 Ivanka pri Nitre

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)		Súlady
	CO	NO _x	CO	NO _x	CO	NO _x	
NP1	-	-	-	-	100	75	✓
NP2	-	-	-	-	100	370	✓
NP3	-	-	-	-	100	370	✓
NP4	-	-	-	-	100	370	✓

Vysvetlivky

PMH Priemerná mesačná hodnota

✓ Hodnoty vyprodukovaných emisií sú v súlade s integrovaným povolením