

## VYPRODUKOVANÉ EMISIE SEPTEMBER 2019

### Kompresorová stanica 01 Veľké Kapušany

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )		Súlada
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	
NP	-	-	-	-	100	75	✓
CR1	0.277	4.113	2.61	65.18	100	75	✓
CR3	0.658	2.385	15.84	63.21	100	75	✓
CR4	0.881	5.741	6.55	63.86	100	75	✓
R5	0.646	3.247	6.66	35.75	100	75	✓
R6	0.668	2.399	7.74	30.29	100	75	✓

### Kompresorová stanica 02 Jablonov nad Turňou

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )		Súlada
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	
CR1	-	-	-	-	100	150	✓
CR2	-	-	-	-	100	150	✓

### Kompresorová stanica 03 Veľké Zlievce

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )		Súlada
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	
NP1	0.003	0.006	14.88	41.32	100	75	✓
NP2	-	-	-	-	100	75	✓
R1	0.041	0.007	38.45	45.35	100	75	✓
R2	-	-	-	-	100	75	✓

### Kompresorová stanica 04 Ivanka pri Nitre

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )		Súlada
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	
NP1	-	-	-	-	100	75	✓
NP2	-	-	-	-	100	370	✓
NP3	-	-	-	-	100	370	✓
NP4	-	-	-	-	100	370	✓

#### Vysvetlivky

**PMH** Priemerná mesačná hodnota

✓ Hodnoty vyprodukovaných emisií sú v súlade s integrovaným povolením