

VYPRODUKOVANÉ EMISIE MÁJ 2020

Kompresorová stanica 01 Veľké Kapušany

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)		Súlada
	CO	NO _x	CO	NO _x	CO	NO _x	
NP	1.082	2.830	10.61	48.61	100	75	✓
CR1	0.121	0.251	2.42	68.41	100	75	✓
CR3	0.181	0.228	16.94	62.52	100	75	✓
CR4	-	-	-	-	100	75	✓
R5	0.018	0.099	5.75	31.58	100	75	✓
R6	1.242	3.221	10.55	32.74	100	75	✓

Kompresorová stanica 02 Jablonov nad Turňou

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)		Súlada
	CO	NO _x	CO	NO _x	CO	NO _x	
CR1	-	-	-	-	100	150	✓
CR2	-	-	-	-	100	150	✓

Kompresorová stanica 03 Veľké Zlievce

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)		Súlada
	CO	NO _x	CO	NO _x	CO	NO _x	
NP1	-	-	0.004	0.017	100	75	✓
NP2	0.522	0.740	24.13	35.39	100	75	✓
R1	0.482	0.724	34.94	53.92	100	75	✓
R2	0.479	1.017	21.69	51.78	100	75	✓

Kompresorová stanica 04 Ivanka pri Nitre

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)		Súlada
	CO	NO _x	CO	NO _x	CO	NO _x	
NP1	-	-	-	-	100	75	✓
NP2	-	-	-	-	100	370	✓
NP3	-	-	-	-	100	370	✓

Vysvetlivky

PMH Priemerná mesačná hodnota

✓ Hodnoty vyprodukovaných emisií sú v súlade s integrovaným povolením