

## VYPRODUKOVANÉ EMISIE NOVEMBER 2020

### Kompresorová stanica 01 Veľké Kapušany

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )		Súlada
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	
NP	1.461	3.980	13.51	47.15	100	75	✓
CR1	0.181	2.059	3.08	58.40	100	75	✓
CR3	0.098	0.044	18.34	51.36	100	75	✓
CR4	0.265	1.664	7.22	46.12	100	75	✓
R5	0.696	4.290	6.81	41.63	100	75	✓
R6	0.137	0.563	7.94	34.21	100	75	✓

### Kompresorová stanica 02 Jablonov nad Turňou

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )		Súlada
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	
CR1	-	-	-	-	100	150	✓
CR2	-	-	-	-	100	150	✓

### Kompresorová stanica 03 Veľké Zlievce

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )		Súlada
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	
NP1	0.037	0.046	-	-	100	75	✓
NP2	0.007	0.016	-	-	100	75	✓
R1	0.178	0.086	67.96	47.05	100	75	✓
R2	0.063	0.033	-	-	100	75	✓

### Kompresorová stanica 04 Ivanka pri Nitre

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )		Súlada
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	
NP1	0.045	0.063	-	-	100	75	✓
NP2	0.015	0.416	10.83	313.03	100	370	✓
NP3	-	-	-	-	100	370	✓

#### Vysvetlivky

**PMH** Priemerná mesačná hodnota

✓ Hodnoty vyprodukovaných emisií sú v súlade s integrovaným povolením