

VYPRODUKOVANÉ EMISIE SEPTEMBER 2020

Kompresorová stanica 01 Veľké Kapušany

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)		Súlada
	CO	NO _x	CO	NO _x	CO	NO _x	
NP	0.205	0.300	14.94	38.67	100	75	✓
CR1	0.022	0.007	-	-	100	75	✓
CR3	0.029	0.006	-	-	100	75	✓
CR4	0.031	0.019	-	-	100	75	✓
R5	-	-	-	-	100	75	✓
R6	0.088	0.410	4.83	31.22	100	75	✓

Kompresorová stanica 02 Jablonov nad Turňou

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)		Súlada
	CO	NO _x	CO	NO _x	CO	NO _x	
CR1	-	-	-	-	100	150	✓
CR2	-	-	-	-	100	150	✓

Kompresorová stanica 03 Veľké Zlievce

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)		Súlada
	CO	NO _x	CO	NO _x	CO	NO _x	
NP1	-	-	-	-	100	75	✓
NP2	-	-	-	-	100	75	✓
R1	0.011	0.013	-	-	100	75	✓
R2	-	-	-	-	100	75	✓

Kompresorová stanica 04 Ivanka pri Nitre

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)		Súlada
	CO	NO _x	CO	NO _x	CO	NO _x	
NP1	0.023	0.080	7.98	46.35	100	75	✓
NP2	0.005	0.225	7.48	334.44	100	370	✓
NP3	-	-	-	-	100	370	✓

Vysvetlivky

PMH Priemerná mesačná hodnota

✓ Hodnoty vyprodukovaných emisií sú v súlade s integrovaným povolením