

VYPRODUKOVANÉ EMISIE AUGUST 2021

Kompresorová stanica 01 Veľké Kapušany

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)		Súlada
	CO	NO _x	CO	NO _x	CO	NO _x	
NP	0.027	0.051	24.03	45.18	100	75	✓
CR1	0.028	0.052	2.85	58.52	100	75	✓
CR3	0.045	0.099	8.10	65.66	100	75	✓
CR4	0.049	0.195	6.17	51.17	100	75	✓
R5	1.502	3.519	11.44	27.17	100	75	✓
R6	-	-	-	-	100	75	✓

Kompresorová stanica 02 Jablonov nad Turňou

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)		Súlada
	CO	NO _x	CO	NO _x	CO	NO _x	
CR1	-	-	-	-	100	150	✓
CR2	-	-	-	-	100	150	✓

Kompresorová stanica 03 Veľké Zlievce

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)		Súlada
	CO	NO _x	CO	NO _x	CO	NO _x	
NP1	-	-	-	-	100	75	✓
NP2	0.004	0.012	-	-	100	75	✓
R1	-	-	-	-	100	75	✓
R2	0.020	0.024	22.00	28.82	100	75	✓

Kompresorová stanica 04 Ivanka pri Nitre

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)		Súlada
	CO	NO _x	CO	NO _x	CO	NO _x	
NP1	0.184	0.253	-	-	100	75	✓
NP2	0.008	0.263	8.70	318.67	100	370	✓
NP3	-	-	-	-	100	370	✓

Vysvetlivky

PMH Priemerná mesačná hodnota

✓ Hodnoty vyprodukovaných emisií sú v súlade s integrovaným povolením