

## VYPRODUKOVANÉ EMISIE FEBRUÁR 2021

### Kompresorová stanica 01 Veľké Kapušany

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )		Súlada
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	
NP	1.469	3.089	21.92	43.88	100	75	✓
CR1	-	-	-	-	100	75	✓
CR3	-	-	-	-	100	75	✓
CR4	0.027	0.008	21.17	54.01	100	75	✓
R5	-	-	-	-	100	75	✓
R6	-	-	-	-	100	75	✓

### Kompresorová stanica 02 Jablonov nad Turňou

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )		Súlada
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	
CR1	-	-	-	-	100	150	✓
CR2	-	-	-	-	100	150	✓

### Kompresorová stanica 03 Veľké Zlievce

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )		Súlada
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	
NP1	0.035	0.059	-	-	100	75	✓
NP2	0.012	0.035	-	-	100	75	✓
R1	0.050	0.020	-	-	100	75	✓
R2	0.038	0.015	-	-	100	75	✓

### Kompresorová stanica 04 Ivanka pri Nitre

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )		Súlada
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	
NP1	-	-	-	-	100	75	✓
NP2	0.005	0.186	11.03	283.75	100	370	✓
NP3	-	-	-	-	100	370	✓

#### Vysvetlivky

**PMH** Priemerná mesačná hodnota

✓ Hodnoty vyprodukovaných emisií sú v súlade s integrovaným povolením